



HAL
open science

Removal of emerging micropollutants from wastewater discharges by powdered and micro-grain activated carbon - Progress of the CarboPlus® project

Romain Mailler, Johnny Gasperi, Yves Coquet, Steven Deshayes, Sifax Zedek, Audrey Buleté, Emmanuelle Vulliet, Véronique Eudes, Adèle Bressy, Emilie Caupos, et al.

► To cite this version:

Romain Mailler, Johnny Gasperi, Yves Coquet, Steven Deshayes, Sifax Zedek, et al.. Removal of emerging micropollutants from wastewater discharges by powdered and micro-grain activated carbon - Progress of the CarboPlus® project. SETAC Europe 25th Annual Meeting, SETAC, May 2015, Barcelone, Spain. hal-01150402

HAL Id: hal-01150402

<https://enpc.hal.science/hal-01150402>

Submitted on 11 May 2015

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Removal of emerging micropollutants from wastewater discharges by powdered and micro-grain activated carbon - Progress of the CarboPlus® project

R. Mailler¹, J. Gasperi¹, Y. Coquet², S. Deshayes^{1,3}, S. Zedek¹, A. Buleté⁴, E. Vulliet⁴, V. Eudes³, A. Bressy¹, E. Caupos¹, R. Moillon¹, G. Chebbo¹ and V. Rocher⁵

¹LEESU, 61 avenue du Général de Gaulle, 94010 Créteil Cedex, France

²SAUR, 1 rue Antoine Lavoisier, 78064 Guyancourt, France

³LCPP, 39 bis rue de Dantzig, 75015 Paris, France

⁴ISA-CNRS, 5 rue de la Doua, 69100 Villeurbanne, France

⁵SIAAP, 82 avenue Kléber, 92700 Colombes, France

E-mail contact: romain.mailler@leesu.enpc.fr

1. Introduction

Among the solutions to reduce the emerging contaminant discharges into the environment, the implementation of a tertiary treatment in actual wastewater treatment plants (WWTP) is more and more considered. Besides, emerging micropollutants, particularly pharmaceuticals and hormones (PhPHs), may be included in modifications of existing regulations.

In this context, a collaboration between the SIAAP and the OPUR research program has been initiated since 2013 to study at large scale a tertiary treatment pilot (CarboPlus® - SAUR/STEREAU) based on a fluidized bed activated carbon reactor. The objectives of this project are to i) characterize the efficiency of the process for priority and emerging pollutants removal, ii) characterize the sorption mechanism and the different parameters influencing it (organic matter competition, operating parameters, activated carbon structure and properties, etc.) and iii) determine if any improvement of the conventional quality parameters is achieved thanks to the process.

The process was initially tested with powdered activated carbon (PAC) and its performances in this configuration are already published [1]. Then, a micro-grain activated carbon (μ GAC) is studied instead of PAC since January 2014. In addition to being reactivable, its intermediary size (300-500 μ m) between powder (<50 μ m) and grain (>1 mm) results in a simplification of the process operation, as no coagulant and flocculant are needed anymore to stabilize the bed.

To evaluate the treatment in the μ GAC configuration, the fate of 131 micropollutants has been studied, including 61 PhPHs and 70 other emerging pollutants, in addition to various conventional wastewater parameters, such as DOC, TSS, UV-254 or nitrogen species.

This presentation aims at displaying the efficiency of this innovative process in a large WWTP application. Thus, the concentrations and the removals obtained with μ GAC for a wide range of emerging micropollutants are presented. Then, the comparison of the two configurations (PAC versus μ GAC) and with the scarce studies available in the literature is given [2][3][4]. Finally, the influence of the various parameters that affect the adsorption of micropollutants in the process is discussed, as well as the results of complementary lab-scale experiments performed to better understand adsorption mechanisms.

2. Materials and methods

The process studied is the CarboPlus® process (SAUR - STEREAU). This technology is based on the flowing of water through a high concentration fluidized activated carbon bed (>100 kg/m³) with a continuous injection of a moderate fresh dose of activated carbon. The pilot studied (5 m high - surface area of 4 m²) is fed with the discharges of the Seine Centre WWTP (Colombes, France - 240 000 m³/day) and can treat between 700 and 1900 m³/day, corresponding to hydraulic velocities of 6 to 20 m/h.

The project was divided in two configurations: 1) PAC in 2013 and 2) μ GAC in 2014. A total of 28 (14 + 14) sampling campaigns were planned, using refrigerated automatic samplers performing 24 h flow weighted composite samples from inlet and outlet waters of the pilot.

Various general water quality parameters were analysed by the SIAAP laboratory (French accreditation) to characterize the effluents and determine if the process allows a general improvement of the water quality. Thus, dissolved organic carbon, chemical and biological oxygen demand, UV absorbance at 254 nm, total Kjeldahl nitrogen, NH₄⁺, NO₂⁻, NO₃⁻, PO₄³⁻, total phosphor and total suspended solids (TSS) were monitored.

A total of 131 organic micropollutants were monitored including 61 pharmaceuticals (analgesics, antibiotics, anxiolytics, X-ray contrast agents) and hormones, and 70 various emerging pollutants such as pesticides (N=28), alkylphenols (N=7), phthalates (N=4), personal care products (N=7), artificial sweeteners (N=4), polycyclic aromatic hydrocarbons (N=13), chlorinated solvents (N=3), perfluorinated acids (N=2) or bisphenol A and benzotriazole. The analyses are performed by 5 laboratories: the Institute of Analytical Sciences (ISA), the Water Environment and Urban Systems laboratory (LEESU), the Central laboratory of the Police Prefecture (LCPP), the CARSO laboratory and the Water Technology Center (TZW - Germany).

3. Results and discussion

After a period of stabilization, high removals of the emerging micropollutants are reached thanks to the CarboPlus® - μ GAC process, with a fresh μ GAC dose of 20 g/m³. Indeed, the 20 PhPHs quantified in influents are all removed at more than 70%. In particular, ketoprofen, paracetamol, ibuprofen, ofloxacin, ciprofloxacin, trimethoprim, roxithromycin, atenolol, propranolol, carbamazepine, oxazepam, lorazepam and estrone have removals higher than 80% in average. In addition, first results on the other emerging micropollutants show high or very high removals for diuron, terbutryn and mecoprop (60-95%), bisphenol A (60-70%), alkylphenols (60-95%), PFOS (75-95%) and X-ray contrast agents (50-70%). Finally, the general quality of the water is significantly improved thanks to the pilot. In particular, the μ GAC bed seems to trap a part of the TSS (36% in average) and to remove a high quantity of organic matter (DOC - 35%; COD - 43%). Moreover, the high solid retention time (60-90 days) of the μ GAC results in a biological activity within the reactor, as displayed by NO₂⁻ (91%) and NH₄⁺ (44%) average removals.

Although these results are preliminary (not all campaigns and molecules), they tend to highlight a comparable efficiency of the CarboPlus® process in both PAC and μ GAC configuration. In addition, they are in accordance with the scarce recent studies available in the literature [2][3][4], despite differences in processes and quality of waters. If this is confirmed with the remaining campaigns (μ GAC dose of 10 g/m³), this would mean that the μ GAC allows similar performances with an operation simplification and a reactivity of the carbon.

The BET surface was confirmed as the most relevant activated carbon structural property to predict the efficiency of adsorption, but comparison of different activated carbons showed that bulk density was correlated to it and could be used as a tool to select the most efficient activated carbons.

4. Conclusions

The use of micro-grain activated carbon instead of PAC has several operational and economical advantages, but this type of carbon was never tested with wastewater. The first results of the study tend to indicate that the CarboPlus® process is as efficient with μ GAC than with PAC despite the higher granulometry of the first one. In particular, most of the studied micropollutants have removals higher than 80% within this process, particularly the PhPHs. In addition, this operation configuration allows to improve slightly the treatment of nutrients, in particular carbon and nitrogen. However, the results are still partial at this stage of the project, another μ GAC dose is currently tested on the pilot and complementary lab-scale tests are still performed to better understand the adsorption mechanisms.

5. References

- [1] R. Mailler, J. Gasperi, Y. Coquet, S. Deshayes, S. Zedek, C. Cren-Olivé, N. Cartiser, V. Eudes, A. Bressy, E. Caupos, R. Moilleron, G. Chebbo and V. Rocher. 2014. Study of a large scale powdered activated carbon pilot: removals of a wide range of emerging and priority micropollutants from wastewater treatment plant effluents. *Water Research* (0).
- [2] M. Bohler, B. Zwicklenpflug, J. Hollender, T. Ternes, A. Joss and H. Siegrist. 2012. Removal of micropollutants in municipal wastewater treatment plants by powder-activated carbon. *Water Sci Technol* 66:2115-2121.
- [3] J. Margot, C. Kienle, A. Magnet, M. Weil, L. Rossi, L.F. de Alencastro, C. Abbeglen, D. Thoney, N. Chèvre, M. Shärer and D.A. Barry. 2013. Treatment of micropollutants in municipal wastewater: Ozone or powdered activated carbon? *Science of the Total Environment* 461-462:480-498.
- [4] J. Altmann, A.S. Ruhl, F. Zietzschmann and M. Jekel. 2014. Direct comparison of ozonation and adsorption onto powdered activated carbon for micropollutant removal in advanced wastewater treatment. *Water Research* 55:185-193.

Acknowledgement - The authors thank the OPUR research program, the SIAAP, LEESU and SAUR teams for their active participation to the project, as well as Yen Pham (internship).